

16.7 Hz - The Missing Link?



Prof. István Erlich

University of Duisburg-Essen


Bremen, January 2014



Current Concept




Current Concept



- Separate platform for each wind farm plus one additional HVDC Platform, both offshore
- 150 kV AC for wind farm connections ➔ voltage too low for considerable power transmission
- Converter technique is located offshore ➔ reliability concerns



Alternative Concept 16 $\frac{2}{3}$ Hz




- 220 kV AC cable for power transmission to onshore
- 220 kV AC suitable for a meshed North Sea grid
- Separate platform for each wind farm but no need for HVDC platform
- No converter offshore



Cable Losses at Low Frequency

Losses at $I_{n_50\text{Hz}} = 2483 \text{ A}$



Alternative Concept $16\frac{2}{3}$ Hz




Converter onshore:

- Converter is not separated in offshore and onshore but back-to-back
- Not affected by sea climate
- Maintenance fast and to lower costs possible
- Mashed offshore grid easy to establish




Wind Turbines

DFIG Type 3



Change to $16\frac{2}{3}$ Hz is difficult,
 $16\frac{2}{3}$ Hz DFIG is too heavy

Full rated WT Type 4



Change to $16\frac{2}{3}$ Hz is easily
 accomplished





16⅔ - 50 Hz Converter

Already developed for single phase

Example Datteln

50 Hz side: 4x103 MW
With overload: 138 MW
Nominal: 413 MW


103 (138) MW unit



245 kV Cable



245 kV Submarine Cable 1200 mm² Cu/RM



245 kV three phase XLPE submarine cable up to 2000 mm² Al and 1600 mm² Cu are available or can be built



245 kV Cable




245 kV Submarine Cables

	2000 mm ² Al/RE		1200 mm ² Cu/RM	
Parameter	50 Hz	16 ² / ₃ Hz	50 Hz	16 ² / ₃ Hz
I _{max} / kA	1.3	1.6 (1.5)	1.3	1.6 (1.5)
S _n /MVA	498	623.8	504.1	610
R'/mΩ/km	38	22.2	31.9	20.4
L'/mH/km	0.34	0.34	0.37	0.37
X'/mΩ/km	107	37	117	39
C'/nF/km	227	227	191	191
G'/nS/km	71	22	60	20




Calculation of Transmission Capacity




Shunt reactors are calculated for full compensation of the cable under no load conditions

$$X_R = 2 \cdot \frac{1}{2\pi f \cdot C'_{\text{cable}} \cdot l}$$

Example: 1200 mm² Cu/RM Cable, 400 km distance




Calculation of Transmission Capacity




Shunt reactors are calculated for full compensation of the cable under no load conditions

$$X_R = 2 \cdot \frac{1}{2\pi f \cdot C'_{\text{cable}} \cdot l}$$

Example: 1200 mm² Cu/RM Cable, 400 km distance




Calculation of Transmission Capacity




*1200 mm² Cu/RM Cable, $I_{max}=1500$ A, 400 km distance
Var demand supplied solely from the grid side*

Transmission Capacity: $P_{Wind} = 589$ MW $P_{Loss} = 8.1\%$




Calculation of Transmission Capacity




*1200 mm² Cu/RM Cable, $I_{max}=1500$ A, 400 km distance
Var demand distributed equally to both ends*

Transmission Capacity: $P_{Wind} = 604$ MW $P_{Loss} = 8.4\%$




Calculation of Transmission Capacity



*1200 mm² Cu/RM Cable, $I_{max}=1500$ A, 400 km distance
optimized operation for max. active power transmission*

Transmission Capacity: $P_{Wind} = 610$ MW $P_{Loss} = 8.5\%$





Transmission Characteristic


245 kV Submarine Cable 2000 mm² Al/RE

Voltage and voltage angle
transmission of 600 MW over 400 km

Compensation demand




Hypothetic Nord Sea Grid



**Meshed North Sea
Grid with $16\frac{2}{3}$ Hz
at 220 kV level
would be possible!**



Power Flow in the North Sea Grid



Assumed total generation power: 5000 MW

- Acceptable voltage drops
- Voltage angle differences are small
- Losses are acceptable



16⅔ Hz Transformer




- Experience in building 16⅔ Hz transformers are available
- Weight is about 2x more than that of 50 Hz transformers

16⅔ Hz Transformer, 15 MVA;
120/17,25 kV, ONAN-Hermetik; Ii0
(Quelle: Alstrom)



Transmission Capacity of 400 kV Overhead Lines



Conductor: 4xAl/St 550/70


$R' = 0,01315 \text{ Ohm/km}$; $X' = 0,26 \text{ Ohm/km}$; $C' = 0,014 \text{ } \mu\text{F/km}$

$I_{\max} = 4080 \text{ A}$



Transmission Capacity of 500 kV Overhead Lines

Power Transmission Capacity





Conductor: 4xAl/St 550/70

$R' = 0,01315 \text{ Ohm/km}$; $X' = 0,26 \text{ Ohm/km}$; $C' = 0,014 \text{ } \mu\text{F/km}$


$I_{\max} = 4080 \text{ A}$



Dynamic Simulation



(a) Reference Power Flow in 16.7 Hz Grid




(b) Reference Reactive Power Flow in 50 Hz Grid




Simulation Results – 16.7 Hz side

Sending End



Simulation Results – 50 Hz side



Conclusions

The integration of offshore wind farms by three phase $16\frac{2}{3}$ Hz technology and setting up a $16\frac{2}{3}$ Hz offshore grid is a favorable alternative to DC links

- Converter are only onshore, easy to access and not affected by serious weather conditions
- No need for HVDC platform offshore
- Offshore are only approved technologies like transformer and switch gears
- Due to meshed 220 kV grid (n-1) security is possible
- Extension to 400 kV (500 kV) onshore overlay grid is possible by $16\frac{2}{3}$ -Hz technology



Thank you for your attention!

